

COMMISSION ACTION

NCPC File No. 6650



UNITED STATES DEPARTMENT OF TREASURY
PERIMETER SECURITY
15th Street, NW and Pennsylvania Avenue, NW
Washington, DC

Submitted by the General Services Administration

April 6, 2006

Commission Action Requested by Applicant

Approval of concept site and building plans pursuant to 40 U.S.C. § 8722(b)(1) and (d).

Commission Action

The Commission:

Comments favorably on the concept site development plans for perimeter security for the Department of Treasury Main Building, as shown on NCPC Map File No. 1.31(38.00)41995.

Recommends implementation of the option that would place a bench in front of the historic building yard fence at the northeast corner of the site, facing Pennsylvania Avenue, NW.

Recommends a preferred spacing of five feet on center between structural members, or a minimum of four feet clearance between finished bollards in areas where the security line crosses pedestrian routes at the sidewalk near 15th Street and Pennsylvania Avenue, and at crosswalks and handicap curb ramps along 15th Street, NW and Hamilton Place, NW.

Deborah B. Young
Secretary to the National Capital Planning Commission