

# COMMISSION ACTION

NCPC File No. 6762



---

**NEBRASKA AVENUE COMPLEX  
CAMPUS SECURITY UPGRADES**  
Nebraska Avenue, NW at Massachusetts Avenue, NW  
Washington, D.C.

Submitted by the General Services Administration

August 2, 2007

---

*Commission Action Requested by Applicant*

Approval of comments on concept site and building plans pursuant to 40 U.S.C. § 8722(b)(1) and (d).

---

*Commission Action*

The Commission:

Regarding concept site and building plans for new and replacement fencing, four new guard booths and two new screening facilities at the Nebraska Avenue Complex (NAC), as shown on NCPC Map File No. 10.03(38.40)42301, requires that the applicant:

- Identify impacts of pole mounted cameras, site lighting, and lighting for the vehicle screening building, on Ward Circle and the Glover-Archbold Park in the preliminary submission package.
  - Submit visual simulations or renderings as well as technical information expressed in lumens to demonstrate any lighting spill-over beyond the property line.
- Show shuttle bus routes, wayfinding signs, and drop-off locations as well as an overall vehicle circulation plan sufficient to clarify the intention and to demonstrate that shifting shuttle bus drop-off points will not adversely impact Ward Circle or the traffic pattern.

**Advises** the applicant that the additional information on lighting is required to determine whether the project would meet the Commission's criteria for categorical exclusion under the National Environmental Policy Act.

---

Deborah B. Young  
Secretary to the National Capital Planning Commission